

LOCATION: _____ Installed by: _____ _____ _____ Per NFPA Standard <input type="checkbox"/> 72 - Local <input type="checkbox"/> 72 - Auxiliary <input type="checkbox"/> 72 - Remote Station <input type="checkbox"/> 72 - Proprietary <input type="checkbox"/> 72 - Central Station Dated _____ For Service Contact: _____ _____ _____ _____ Inspected By: _____ _____ _____ _____ Date: _____ Power Supply: Primary _____ Location _____ Fuses _____ Secondary _____ Type _____ Specs _____	<div style="background-color: black; color: white; padding: 5px; text-align: center; font-weight: bold;">OPERATING INSTRUCTIONS</div> <p style="text-align: center; font-weight: bold;">FIRE ALARM CONTROL PANEL</p> <p>NORMAL CONDITION: POWER LED (GREEN) ON, ALL OTHER LEDs OFF.</p> <p>ALARM CONDITION: SYSTEM ALARM LED (RED), ALARM LOCATION AND ZONE SHOWN IN DISPLAY. USE REVIEW ALARM QUEUE SWITCH TO VIEW ADDITIONAL ALARMS. INTERNAL BUZZER PULSING.</p> <p>1. TO SILENCE AUDIBLE DEVICES: PRESS THE "ALARM SILENCE" SWITCH. AUDIBLE SIGNALS WILL TURN OFF. NEW ALARMS RE-SOUND AUDIBLE SIGNALS. TO RE-SOUND AUDIBLE SIGNALS, PRESS THE "ALARM SILENCE" SWITCH A SECOND TIME.</p> <p>2. TO RESET SYSTEM: PRESS "RESET" SWITCH (AFTER INVESTIGATING ALARM CONDITION).</p> <p>SUPERVISORY CONDITION: SUPERVISORY LED (YELLOW), INTERNAL BUZZER ON. SUPERVISORY CONDITION, LOCATION, AND ZONE SHOWN IN DISPLAY. USE REVIEW SUPERVISORY QUEUE BUTTON TO VIEW ADDITIONAL LOCATIONS. INTERNAL BUZZER PULSING.</p> <p>1. TO SILENCE BUZZER: PRESS "PANEL SILENCE" BUTTON. INVESTIGATE CAUSE.</p> <p>2. TO CLEAR SYSTEM: PRESS THE "RESET" SWITCH.</p> <p>MONITOR CONDITION: MONITOR LED (YELLOW) ON IN NON ALARM. MONITOR CONDITION AND LOCATION SHOWN IN DISPLAY ONLY IN ALARM. USE REVIEW MONITOR QUEUE BUTTON TO VIEW ADDITIONAL LOCATIONS.</p> <p>1. TO CLEAR SYSTEM: SYSTEM CLEARS AUTOMATICALLY ON RESTORATION OF MONITOR CONDITION.</p> <p>TROUBLE CONDITION: SYSTEM TROUBLE LED (YELLOW) ON. INTERNAL BUZZER PULSING. TROUBLE LOCATION AND ZONE SHOWN IN DISPLAY. USE REVIEW TROUBLE QUEUE BUTTON TO VIEW ADDITIONAL LOCATIONS.</p> <p>1. TO SILENCE BUZZER: PRESS "LOCAL SILENCE" SWITCH. INVESTIGATE CAUSE OF TROUBLE.</p> <p>2. TO CLEAR SYSTEM: SYSTEM CLEAR AUTOMATICALLY ON CORRECTION OF TROUBLE CONDITION.</p> <p>FIRE DRILL: NOTIFY FIRE DEPARTMENT OF TEST.</p> <p>1. TO DRILL AND SOUND ALL AUDIBLE DEVICES: PRESS DRILL BUTTON. ALL AUDIBLE VISIBLE SIGNALS OPERATE. PRESS DRILL A SECOND TIME OR ALARM SILENCE TO END DRILL.</p> <p style="text-align: center; font-size: small;">FOR ADDITIONAL INFORMATION, REFER TO MANUAL P/N 270382 THESE INSTRUCTIONS TO BE FRAMED AND MOUNTED ADJACENT TO CONTROL PANEL.</p> <p style="text-align: right; font-size: x-small;">[Operating Instructions CDR]</p>
---	---